

Analytical ReportBill To: School District #35
20260 - 64 Avenue
Langley, BC, Canada
V3A 4P7

Attn: Accounts Payable

Sampled By:

Company:

Project ID:
Project Name:
Project Location:
LSD:
P.O.: S00023
Proj. Acct. code:Lot ID: **1440389**
Control Number:
Date Received: Aug 14, 2020
Date Reported: Aug 19, 2020
Report Number: 2538866

Analyte	Lead
Description	Element
Unit of Measure	mg/L
Nominal Detection Limit	0.00001

Sample Id	Description	Results	Guideline Limit	Guideline Comments
7165473	Glenwood / Rm 24 / Static	0.0099	0.005	Above MAC
7165474	Glenwood / Rm 24 / Flushed	0.0022	0.005	Below MAC
7165475	Glenwood / Rm 25 / Static	0.0025	0.005	Below MAC
7165476	Glenwood / Rm 25 / Flushed	0.0018	0.005	Below MAC

Approved by:

Max Hewitt

Analytical Report

Bill To: School District #35
20260 - 64 Avenue
Langley, BC, Canada
V3A 4P7

Attn: Accounts Payable

Sampled By:

Company:

Project ID:
Project Name:
Project Location:
LSD:
P.O.: S00023
Proj. Acct. code:Lot ID: **1440389**
Control Number:
Date Received: Aug 14, 2020
Date Reported: Aug 19, 2020
Report Number: 2538871

Analyte	Lead
Description	Element
Unit of Measure	mg/L
Nominal Detection Limit	0.00001

Sample Id	Description	Results	Guideline Limit	Guideline Comments
7165501	Nickomekl / Rm 4 / Static	0.0014	0.005	Below MAC
7165502	Nickomekl / Rm 4 / Flushed	0.00054	0.005	Below MAC
7165503	Nickomekl / Rm 9 / Static	0.0068	0.005	Above MAC
7165504	Nickomekl / Rm 9 / Flushed	0.025	0.005	Above MAC
7165505	Nickomekl / Rm 15 / Static	0.00095	0.005	Below MAC
7165506	Nickomekl / Rm 15 / Flushed	0.00062	0.005	Below MAC

Approved by:



Max Hewitt

Analytical Report

Bill To: School District #35
20260 - 64 Avenue
Langley, BC, Canada
V3A 4P7

Attn: Accounts Payable

Sampled By:
Company:

Project ID:
Project Name:
Project Location:
LSD:
P.O.: S00023
Proj. Acct. code:

Lot ID: **1440389**
Control Number:
Date Received: Aug 14, 2020
Date Reported: Aug 19, 2020
Report Number: 2538870

Analyte	Lead
Description	Element
Unit of Measure	mg/L
Nominal Detection Limit	0.00001

Sample Id	Description	Results	Guideline Limit	Guideline Comments
7165495	Douglas Park / Rm 13 / Static	0.024	0.005	Above MAC
7165496	Douglas Park / Rm 13 / Flushed	0.0055	0.005	Above MAC
7165497	Douglas Park / Rm 23 / Static	0.00061	0.005	Below MAC
7165498	Douglas Park / Rm 23 / Flushed	0.00028	0.005	Below MAC
7165499	Douglas Park / Rm 2 / Static	0.0065	0.005	Above MAC
7165500	Douglas Park / Rm 2 / Flushed	0.0011	0.005	Below MAC

Approved by:

Max Hewitt



Analytical Report

Bill To: School District #35
20260 - 64 Avenue
Langley, BC, Canada
V3A 4P7

Attn: Accounts Payable

Sampled By:
Company:

Project ID:
Project Name:
Project Location:
LSD:
P.O.: S00023
Proj. Acct. code:

Lot ID: **1440389**
Control Number:
Date Received: Aug 14, 2020
Date Reported: Aug 19, 2020
Report Number: 2538872

Analyte	Lead
Description	Element
Unit of Measure	mg/L
Nominal Detection Limit	0.00001

Sample Id	Description	Results	Guideline Limit	Guideline Comments
7165507	Uplands / Rm 2 / Static	0.017	0.005	Above MAC
7165508	Uplands / Rm 2 / Flushed	0.0013	0.005	Below MAC
7165509	Uplands / Rm 8 / Static	0.0028	0.005	Below MAC
7165510	Uplands / Rm 8 / Flushed	0.0011	0.005	Below MAC
7165511	Uplands / Rm 15 / Static	0.0098	0.005	Above MAC
7165512	Uplands / Rm 15 / Flushed	0.0047	0.005	Below MAC

Approved by:



Max Hewitt

Analytical ReportBill To: School District #35
20260 - 64 Avenue
Langley, BC, Canada
V3A 4P7Attn: Accounts Payable
Sampled By:
Company:Project ID:
Project Name:
Project Location:
LSD:
P.O.: S00023
Proj. Acct. code:Lot ID: **1440389**
Control Number:
Date Received: Aug 14, 2020
Date Reported: Aug 19, 2020
Report Number: 2538869

Analyte	Lead
Description	Element
Unit of Measure	mg/L
Nominal Detection Limit	0.00001

Sample Id	Description	Results	Guideline Limit	Guideline Comments
7165489	Blacklock / Rm 113 / Static	0.035	0.005	Above MAC
7165490	Blacklock / Rm 113 / Flushed	0.0035	0.005	Below MAC
7165491	Blacklock / Rm 109 / Static	0.0057	0.005	Above MAC
7165492	Blacklock / Rm 109 / Flushed	0.0025	0.005	Below MAC
7165493	Blacklock / Staff Room / Static	0.0012	0.005	Below MAC
7165494	Blackrock / Staff Room / Flushed	0.00034	0.005	Below MAC

Approved by:


Max Hewitt

Analytical Report

Bill To: School District #35
20260 - 64 Avenue
Langley, BC, Canada
V3A 4P7Attn: Accounts Payable
Sampled By:
Company:Project ID:
Project Name:
Project Location:
LSD:
P.O.: S00023
Proj. Acct. code:Lot ID: **1440389**
Control Number:
Date Received: Aug 14, 2020
Date Reported: Aug 19, 2020
Report Number: 2538868

Analyte	Lead
Description	Element
Unit of Measure	mg/L
Nominal Detection Limit	0.00001

Sample Id	Description	Results	Guideline Limit	Guideline Comments
7165483	Langley Fun Elementary / Rm 2 / Static	0.0030	0.005	Below MAC
7165484	Langley Fun Elementary / Rm 2 / Flushed	0.0019	0.005	Below MAC
7165485	Langley Fun Elementary / Rm 11 / Static	0.0030	0.005	Below MAC
7165486	Langley Fun Elementary / Rm 11 / Flushed	0.0064	0.005	Above MAC
7165487	Langley Fun Elementary / Rm 18 / Static	0.0016	0.005	Below MAC
7165488	Langley Fun Elementary / Rm 18 / Flushed	0.0014	0.005	Below MAC

Approved by:


Max Hewitt

Analytical Report

Bill To: School District #35
20260 - 64 Avenue
Langley, BC, Canada
V3A 4P7

Attn: Accounts Payable
Sampled By:
Company:

Project ID:
Project Name:
Project Location:
LSD:
P.O.: S00023
Proj. Acct. code:

Lot ID: **1440389**
Control Number:
Date Received: Aug 14, 2020
Date Reported: Aug 19, 2020
Report Number: 2538867

Analyte	Lead
Description	Element
Unit of Measure	mg/L
Nominal Detection Limit	0.00001

Sample Id	Description	Results	Guideline Limit	Guideline Comments
7165477	West Langley / Rm 6 / Static	0.0018	0.005	Below MAC
7165478	West Langley / Rm 6 / Flushed	0.0010	0.005	Below MAC
7165479	West Langley / Rm 19 / Static	0.0016	0.005	Below MAC
7165480	West Langley / Rm 19 / Flushed	0.00076	0.005	Below MAC
7165481	West Langley / Rm 28 / Static	0.0023	0.005	Below MAC
7165482	West Langley / Rm 28 / Flushed	0.00066	0.005	Below MAC

passed

Approved by:

Max Hewitt



Analytical ReportBill To: School District #35
20260 - 64 Avenue
Langley, BC, Canada
V3A 4P7

Attn: Accounts Payable

Sampled By:

Company:

Project ID:
Project Name:
Project Location:
LSD:
P.O.: S00023
Proj. Acct. code:Lot ID: **1440389**
Control Number:
Date Received: Aug 14, 2020
Date Reported: Aug 19, 2020
Report Number: 2538875

Analyte Description Unit of Measure Nominal Detection Limit	Lead Element mg/L 0.00001
--	------------------------------------

Sample Id	Description	Results	Guideline Limit	Guideline Comments
7165523	Peterson Rd / Rm 22 / Static	0.00082	0.005	Below MAC
7165524	Peterson Rd / Rm 22 / Flushed	0.00038	0.005	Below MAC
7165525	Peterson Rd / Rm 33 / Static	0.00037	0.005	Below MAC
7165526	Peterson Rd / Rm 33 / Flushed	0.00030	0.005	Below MAC
7165557	Peterson Rd / Rm 204 / Static	0.0019	0.005	Below MAC
7165558	Peterson Rd / Rm 204 / Flushed	0.00070	0.005	Below MAC

Passed

Approved by:

Max Hewitt

Analytical ReportBill To: School District #35
20260 - 64 Avenue
Langley, BC, Canada
V3A 4P7

Attn: Accounts Payable

Sampled By:

Company:

Project ID:
Project Name:
Project Location:
LSD:
P.O.: S00023
Proj. Acct. code:Lot ID: **1440389**
Control Number:
Date Received: Aug 14, 2020
Date Reported: Aug 19, 2020
Report Number: 2538873

Analyte	Lead
Description	Element
Unit of Measure	mg/L
Nominal Detection Limit	0.00001

Sample Id	Description	Results	Guideline Limit	Guideline Comments
7165513	Alice Brown / Rm 1 / Static	0.0040	0.005	Below MAC
7165514	Alice Brown / Rm 1 / Flushed	0.00066	0.005	Below MAC
7165515	Alice Brown / Rm 12 / Static	0.0034	0.005	Below MAC
7165516	Alice Brown / Rm 12 / Flushed	0.00079	0.005	Below MAC

Passed

Approved by:

Max Hewitt

Analytical ReportBill To: School District #35
20260 - 64 Avenue
Langley, BC, Canada
V3A 4P7

Attn: Accounts Payable

Sampled By:

Company:

Project ID:
Project Name:
Project Location:
LSD:
P.O.: S00023
Proj. Acct. code:Lot ID: **1440389**
Control Number:
Date Received: Aug 14, 2020
Date Reported: Aug 19, 2020
Report Number: 2538874

Analyte	Lead
Description	Element
Unit of Measure	mg/L
Nominal Detection Limit	0.00001

Sample Id	Description	Results	Guideline Limit	Guideline Comments
7165517	Langley Meadows / Rm 5 / Static	0.00054	0.005	Below MAC
7165518	Langley Meadows / Rm 5 / Flushed	0.00034	0.005	Below MAC
7165519	Langley Meadows / Rm 42 / Static	0.0011	0.005	Below MAC
7165520	Langley Meadows / Rm 42 / Flushed	0.00073	0.005	Below MAC
7165521	Langley Meadows / Rm 46A / Static	0.0020	0.005	Below MAC
7165522	Langley Meadows / Rm 46A / Flushed	0.0014	0.005	Below MAC

Passed

Approved by:



Max Hewitt

Analytical Report

Bill To: School District #35
20260 - 64 Avenue
Langley, BC, Canada
V3A 4P7

Attn: Accounts Payable
Sampled By:
Company:

Project ID:
Project Name:
Project Location:
LSD:
P.O.: S00023
Proj. Acct. code:

Lot ID: **1440389**
Control Number:
Date Received: Aug 14, 2020
Date Reported: Aug 19, 2020
Report Number: 2538744

Analyte	Lead
Description	Element
Unit of Measure	mg/L
Nominal Detection Limit	0.00001

Sample Id	Description	Results	Guideline Limit	Guideline Comments
7165467	Wix Brown / Rm 24 / Static	0.0023	0.005	Below MAC
7165468	Wix Brown / Rm 24 / Flushed	0.00030	0.005	Below MAC
7165469	Wix Brown / Rm 35 / Static	0.00055	0.005	Below MAC
7165470	Wix Brown / Rm 35 / Flushed	0.0015	0.005	Below MAC
7165471	Wix Brown / Staff Room / Static	0.0015	0.005	Below MAC
7165472	Wix Brown / Staff Room / Flushed	0.00039	0.005	Below MAC

PASSED

Approved by:


Max Hewitt