

Analytical Report

Bill To: School District #35
20260 - 64 Avenue
Langley, BC, Canada
V3A 4P7
Attn: Accounts Payable
Sampled By:
Company:

Project ID:
Project Name:
Project Location:
LSD:
P.O.: S00023
Proj. Acct. code:

Lot ID: **1577833**
Control Number:
Date Received: Jun 13, 2022
Date Reported: Jun 17, 2022
Report Number: 2757539

		Reference Number	1577833-35	1577833-36	1577833-37
		Sample Date	Jun 13, 2022	Jun 13, 2022	Jun 13, 2022
		Sample Time	08:00	08:00	08:00
		Sample Location			
		Sample Description	Fort Elementary / Rm 26 / 19.4 °C	Fort Elementary / Rm 26 / 19.4 °C	Fort Elementary / Staff Rm / 19.4 °C
		Matrix	Water	Water	Water
Analyte	Units	Results	Results	Results	Nominal Detection Limit
Metals Extractable					
Lead	Extractable	mg/L	0.0013	0.0012	0.00028
					0.00001

Passed

(.005 and Above.)

Analytical Report

Bill To: School District #35
20260 - 64 Avenue
Langley, BC, Canada
V3A 4P7
Attn: Accounts Payable
Sampled By:
Company:

Project ID:
Project Name:
Project Location:
LSD:
P.O.: S00023
Proj. Acct. code:

Lot ID: **1577833**
Control Number:
Date Received: Jun 13, 2022
Date Reported: Jun 17, 2022
Report Number: 2757539

		Reference Number	1577833-38	1577833-39	1577833-40	
		Sample Date	Jun 13, 2022	Jun 13, 2022	Jun 13, 2022	
		Sample Time	08:00	08:10	08:10	
		Sample Location				
		Sample Description	Fort Elementary / Staff Rm / 19.4 °C	Fort Elementary / Rm 4 / 19.4 °C	Fort Elementary / Rm 4 / 19.4 °C	
		Matrix	Water	Water	Water	
Analyte		Units	Results	Results	Results	Nominal Detection Limit
Metals Extractable						
Lead	Extractable	mg/L	0.00007	0.0018	0.0011	0.00001

Passed

Approved by:

Max Hewitt
Max Hewitt
Operations Manager

Analytical Report

Bill To: School District #35 20260 - 64 Avenue Langley, BC, Canada V3A 4P7	Project ID: Project Name: Project Location: LSD: P.O.: S00023 Proj. Acct. code:	Lot ID: 1577833 Control Number: Date Received: Jun 13, 2022 Date Reported: Jun 17, 2022 Report Number: 2757534
Attn: Accounts Payable Sampled By: Company:		

Reference Number	1577833-9	1577833-10	1577833-11
Sample Date	Jun 13, 2022	Jun 13, 2022	Jun 13, 2022
Sample Time	10:30	10:30	10:30
Sample Location	STAFF RM	STAFF RM	5
Sample Description	Noel Booth / Rm 7 / 19.4 °C	Noel Booth / Rm 7 / 19.4 °C	Noel Booth / Rm 7 / 19.4 °C
Matrix	Water	Water	Water

Analyte	Units	Results	Results	Results	Nominal Detection Limit
Metals Extractable					
Lead	Extractable mg/L	0.00061	0.00032	0.00028	0.00001

passed

Analytical Report

Bill To: School District #35
20260 - 64 Avenue
Langley, BC, Canada
V3A 4P7
Attn: Accounts Payable
Sampled By:
Company:

Project ID:
Project Name:
Project Location:
LSD:
P.O.: S00023
Proj. Acct. code:

Lot ID: **1577833**
Control Number:
Date Received: Jun 13, 2022
Date Reported: Jun 17, 2022
Report Number: 2757358

Reference Number	1577833-7	1577833-8
Sample Date	Jun 13, 2022	Jun 13, 2022
Sample Time	10:20	10:20
Sample Location	Rm 7	Rm 7
Sample Description	Noel Booth / Staff Rm / 19.4 °C	Noel Booth / Staff Rm / 19.4 °C
Matrix	Water	Water

Analyte	Units	Results	Results	Results	Nominal Detection Limit
Metals Extractable					
Lead	Extractable	mg/L	0.00037	0.00047	0.00001

Approved by:


Max Hewitt
Operations Manager

Analytical Report

Bill To: School District #35
20260 - 64 Avenue
Langley, BC, Canada
V3A 4P7
Attn: Accounts Payable
Sampled By:
Company:

Project ID:
Project Name:
Project Location:
LSD:
P.O.: S00023
Proj. Acct. code:

Lot ID: **1577833**
Control Number:
Date Received: Jun 13, 2022
Date Reported: Jun 17, 2022
Report Number: 2757534

Reference Number 1577833-12
Sample Date Jun 13, 2022
Sample Time 10:30
Sample Location **5**
Sample Description Noel Booth / Rm # /
19.4 °C
Matrix Water

Analyte	Units	Results	Results	Results	Nominal Detection Limit
Metals Extractable					
Lead	Extractable mg/L	0.00024			0.00001

Approved by:


Max Hewitt
Operations Manager

Analytical Report

Bill To: School District #35
20260 - 64 Avenue
Langley, BC, Canada
V3A 4P7
Attn: Accounts Payable
Sampled By:
Company:

Project ID:
Project Name:
Project Location:
LSD:
P.O.: S00023
Proj. Acct. code:

Lot ID: **1577833**
Control Number:
Date Received: Jun 13, 2022
Date Reported: Jun 17, 2022
Report Number: 2757538

		Reference Number	1577833-32	1577833-33	1577833-34
		Sample Date	Jun 13, 2022	Jun 13, 2022	Jun 13, 2022
		Sample Time	08:30	08:40	08:40
		Sample Location			
		Sample Description	North Otter / Rm 36 /	North Otter / Rm 42 /	North Otter / Rm 42 /
			19.4 °C	19.4 °C	19.4 °C
		Matrix	Water	Water	Water
Analyte	Units	Results	Results	Results	Nominal Detection Limit
Metals Extractable					
Lead	Extractable	mg/L	0.00071	0.00055	0.00050
					0.00001

Approved by:



Max Hewitt
Operations Manager

Analytical Report

Bill To: School District #35 20260 - 64 Avenue Langley, BC, Canada V3A 4P7	Project ID: Project Name: Project Location: LSD: P.O.: S00023 Proj. Acct. code:	Lot ID: 1577833 Control Number: Date Received: Jun 13, 2022 Date Reported: Jun 17, 2022 Report Number: 2757538
Attn: Accounts Payable Sampled By: Company:		

Reference Number	1577833-29	1577833-30	1577833-31
Sample Date	Jun 13, 2022	Jun 13, 2022	Jun 13, 2022
Sample Time	08:30	08:30	08:30
Sample Location			
Sample Description	North Otter / Rm 10 /	North Otter / Rm 10 /	North Otter / Rm 36 /
	19.4 °C	19.4 °C	19.4 °C
Matrix	Water	Water	Water

Analyte	Units	Results	Results	Results	Nominal Detection Limit
Metals Extractable					
Lead	Extractable mg/L	0.0014	0.00024	0.0010	0.00001

Analytical Report

Bill To: School District #35
20260 - 64 Avenue
Langley, BC, Canada
V3A 4P7
Attn: Accounts Payable
Sampled By:
Company:

Project ID:
Project Name:
Project Location:
LSD:
P.O.: S00023
Proj. Acct. code:

Lot ID: **1577833**
Control Number:
Date Received: Jun 13, 2022
Date Reported: Jun 17, 2022
Report Number: 2757541

		Reference Number	1577833-48	1577833-49	1577833-50
		Sample Date	Jun 14, 2022	Jun 14, 2022	Jun 14, 2022
		Sample Time	07:10	07:15	07:15
		Sample Location			
		Sample Description	James Kennedy / Rm 104 / 19.4 °C	James Kennedy / Rm 106 / 19.4 °C	James Kennedy / Rm 106 / 19.4 °C
		Matrix	Water	Water	Water
Analyte	Units	Results	Results	Results	Nominal Detection Limit
Metals Extractable					
Lead	Extractable	mg/L	0.00011	0.00053	0.00037
					0.00001

Approved by:


Max Hewitt
Operations Manager

Analytical Report

Bill To: School District #35 20260 - 64 Avenue Langley, BC, Canada V3A 4P7	Project ID: Project Name: Project Location: LSD: P.O.: S00023 Proj. Acct. code:	Lot ID: 1577833 Control Number: Date Received: Jun 13, 2022 Date Reported: Jun 17, 2022 Report Number: 2757541
Attn: Accounts Payable Sampled By: Company:		

Reference Number	1577833-45	1577833-46	1577833-47
Sample Date	Jun 13, 2022	Jun 13, 2022	Jun 14, 2022
Sample Time	07:00	07:00	07:10
Sample Location			
Sample Description	James Kennedy / Rm 137 / 19.4 °C	James Kennedy / Rm 137 / 19.4 °C	James Kennedy / Rm 104 / 19.4 °C
Matrix	Water	Water	Water

Analyte	Units	Results	Results	Results	Nominal Detection Limit
Metals Extractable					
Lead	Extractable mg/L	0.0018	0.00081	0.00026	0.00001

Analytical Report

Bill To: School District #35
20260 - 64 Avenue
Langley, BC, Canada
V3A 4P7
Attn: Accounts Payable
Sampled By:
Company:

Project ID:
Project Name:
Project Location:
LSD:
P.O.: S00023
Proj. Acct. code:

Lot ID: **1577833**
Control Number:
Date Received: Jun 13, 2022
Date Reported: Jun 17, 2022
Report Number: 2757537

Reference Number	1577833-25	1577833-26	1577833-27
Sample Date	Jun 13, 2022	Jun 13, 2022	Jun 13, 2022
Sample Time	09:00	09:00	09:00
Sample Location			
Sample Description	Coghlan / Rm 22 / 19.4 °C	Coghlan / Rm 22 / 19.4 °C	Coghlan / Rm 10 / 19.4 °C
Matrix	Water	Water	Water

Analyte	Units	Results	Results	Results	Nominal Detection Limit
Metals Extractable					
Lead	Extractable	mg/L	0.00036	0.00012	0.00009
					0.00001

Analytical Report

Bill To: School District #35
20260 - 64 Avenue
Langley, BC, Canada
V3A 4P7
Attn: Accounts Payable
Sampled By:
Company:

Project ID:
Project Name:
Project Location:
LSD:
P.O.: S00023
Proj. Acct. code:

Lot ID: **1577833**
Control Number:
Date Received: Jun 13, 2022
Date Reported: Jun 17, 2022
Report Number: 2757537

Reference Number 1577833-28
Sample Date Jun 13, 2022
Sample Time 09:00
Sample Location
Sample Description Coghlan / Rm 10 /
19.4 °C
Matrix Water

Analyte	Units	Results	Results	Results	Nominal Detection Limit
Metals Extractable					
Lead	Extractable	mg/L	0.00008		0.00001

Approved by:


Max Hewitt
Operations Manager

Analytical Report

Bill To: School District #35
20260 - 64 Avenue
Langley, BC, Canada
V3A 4P7
Attn: Accounts Payable
Sampled By:
Company:

Project ID:
Project Name:
Project Location:
LSD:
P.O.: S00023
Proj. Acct. code:

Lot ID: **1577833**
Control Number:
Date Received: Jun 13, 2022
Date Reported: Jun 17, 2022
Report Number: 2757358

Reference Number	1577833-1	1577833-2	1577833-3
Sample Date	Jun 13, 2022	Jun 13, 2022	Jun 13, 2022
Sample Time	05:30	05:40	05:40
Sample Location			
Sample Description	Willoughby / Rm 13 / 19.4 °C	Willoughby / Rm 13 / 19.4 °C	Willoughby / Rm 6 / 19.4 °C
Matrix	Water	Water	Water

Analyte		Units	Results	Results	Results	Nominal Detection Limit
Metals Extractable						
Lead	Extractable	mg/L	0.0010	0.00094	0.00056	0.00001

Analytical Report

Bill To: School District #35
20260 - 64 Avenue
Langley, BC, Canada
V3A 4P7
Attn: Accounts Payable
Sampled By:
Company:

Project ID:
Project Name:
Project Location:
LSD:
P.O.: S00023
Proj. Acct. code:

Lot ID: **1577833**
Control Number:
Date Received: Jun 13, 2022
Date Reported: Jun 17, 2022
Report Number: 2757358

		Reference Number	1577833-4	1577833-5	1577833-6
		Sample Date	Jun 13, 2022	Jun 13, 2022	Jun 13, 2022
		Sample Time	05:40	05:50	05:50
		Sample Location			
		Sample Description	Willoughby / Rm 6 / 19.4 °C	Willoughby / Rm 4 / 19.4 °C	Willoughby / Rm 4 / 19.4 °C
		Matrix	Water	Water	Water
Analyte	Units	Results	Results	Results	Nominal Detection Limit
Metals Extractable					
Lead	Extractable	mg/L	0.00070	0.0021	0.00040
					0.00001

Analytical Report

Bill To: School District #35 20260 - 64 Avenue Langley, BC, Canada V3A 4P7	Project ID: Project Name: Project Location: LSD: P.O.: S00023 Proj. Acct. code:	Lot ID: 1577833 Control Number: Date Received: Jun 13, 2022 Date Reported: Jun 17, 2022 Report Number: 2757542
Attn: Accounts Payable Sampled By: Company:		

Reference Number	1577833-51	1577833-52	1577833-53
Sample Date	Jun 13, 2022	Jun 13, 2022	Jun 13, 2022
Sample Time	06:20	06:20	06:30
Sample Location			
Sample Description	Alex Hope / Staff Rm / 19.4 °C	Alex Hope / Staff Rm / 19.4 °C	Alex Hope / East 3 / 19.4 °C
Matrix	Water	Water	Water

Analyte		Units	Results	Results	Results	Nominal Detection Limit
Metals Extractable						
Lead	Extractable	mg/L	0.00065	0.00041	0.00026	0.00001

Analytical Report

Bill To: School District #35
20260 - 64 Avenue
Langley, BC, Canada
V3A 4P7
Attn: Accounts Payable
Sampled By:
Company:

Project ID:
Project Name:
Project Location:
LSD:
P.O.: S00023
Proj. Acct. code:

Lot ID: **1577833**
Control Number:
Date Received: Jun 13, 2022
Date Reported: Jun 17, 2022
Report Number: 2757542

Reference Number	1577833-54	1577833-55	1577833-56
Sample Date	Jun 13, 2022	Jun 13, 2022	Jun 13, 2022
Sample Time	06:30	06:40	06:40
Sample Location	Alex Hope / East 3 /	Alex Hope / West 22	Alex Hope / West 22
Sample Description	19.4 °C	/ 19.4 °C	/ 19.4 °C
Matrix	Water	Water	Water

Analyte		Units	Results	Results	Results	Nominal Detection Limit
Metals Extractable						
Lead	Extractable	mg/L	0.00040	0.00055	0.00023	0.00001

Analytical Report

Bill To: School District #35
20260 - 64 Avenue
Langley, BC, Canada
V3A 4P7
Attn: Accounts Payable
Sampled By:
Company:

Project ID:
Project Name:
Project Location:
LSD:
P.O.: S00023
Proj. Acct. code:

Lot ID: **1577833**
Control Number:
Date Received: Jun 13, 2022
Date Reported: Jun 17, 2022
Report Number: 2757542

Reference Number	1577833-57	1577833-58
Sample Date	Jun 13, 2022	Jun 13, 2022
Sample Time	06:50	06:50
Sample Location		
Sample Description	Alex Hope / South 11 / 19.4 °C	Alex Hope / South 11 / 19.4 °C
Matrix	Water	Water

Analyte	Units	Results	Results	Results	Nominal Detection Limit
Metals Extractable					
Lead	Extractable	mg/L	0.00035	0.00038	0.00001

Approved by:


Max Hewitt
Operations Manager

Analytical Report

Bill To: School District #35
20260 - 64 Avenue
Langley, BC, Canada
V3A 4P7
Attn: Accounts Payable
Sampled By:
Company:

Project ID:
Project Name:
Project Location:
LSD:
P.O.: S00023
Proj. Acct. code:

Lot ID: **1577833**
Control Number:
Date Received: Jun 13, 2022
Date Reported: Jun 17, 2022
Report Number: 2757536

Reference Number	1577833-20	1577833-21	1577833-22
Sample Date	Jun 13, 2022	Jun 13, 2022	Jun 13, 2022
Sample Time	09:30	09:30	09:30
Sample Location			
Sample Description	Shortreed / Rm 112 / 19.4 °C	Shortreed / Rm 105 / 19.4 °C	Shortreed / Rm 105 / 19.4 °C
Matrix	Water	Water	Water

Analyte		Units	Results	Results	Results	Nominal Detection Limit
Metals Extractable						
Lead	Extractable	mg/L	0.0016	0.00061	0.00034	0.00001

Analytical Report

Bill To: School District #35
20260 - 64 Avenue
Langley, BC, Canada
V3A 4P7
Attn: Accounts Payable
Sampled By:
Company:

Project ID:
Project Name:
Project Location:
LSD:
P.O.: S00023
Proj. Acct. code:

Lot ID: **1577833**
Control Number:
Date Received: Jun 13, 2022
Date Reported: Jun 17, 2022
Report Number: 2757536

Reference Number	1577833-17	1577833-18	1577833-19
Sample Date	Jun 13, 2022	Jun 13, 2022	Jun 13, 2022
Sample Time	09:20	09:20	09:30
Sample Location	Shortreed / Rm 107 /	Shortreed / Rm 107 /	Shortreed / Rm 112 /
Sample Description	19.4 °C	19.4 °C	19.4 °C
Matrix	Water	Water	Water

Analyte	Units	Results	Results	Results	Nominal Detection Limit
Metals Extractable					
Lead	Extractable	mg/L	0.00036	0.00039	0.0035
					0.00001

Analytical Report

Bill To: School District #35
20260 - 64 Avenue
Langley, BC, Canada
V3A 4P7
Attn: Accounts Payable
Sampled By:
Company:

Project ID:
Project Name:
Project Location:
LSD:
P.O.: S00023
Proj. Acct. code:

Lot ID: **1577833**
Control Number:
Date Received: Jun 13, 2022
Date Reported: Jun 17, 2022
Report Number: 2757536

Reference Number	1577833-23	1577833-24
Sample Date	Jun 13, 2022	Jun 13, 2022
Sample Time	09:40	09:40
Sample Location		
Sample Description	Shortreed / Staff Rm / 19.4 °C	Shortreed / Staff Rm / 19.4 °C
Matrix	Water	Water

Analyte	Units	Results	Results	Results	Nominal Detection Limit
Metals Extractable					
Lead	Extractable	mg/L	0.00064	0.00041	0.00001

Approved by:


Max Hewitt
Operations Manager

Analytical Report

Bill To: School District #35
20260 - 64 Avenue
Langley, BC, Canada
V3A 4P7
Attn: Accounts Payable
Sampled By:
Company:

Project ID:
Project Name:
Project Location:
LSD:
P.O.: S00023
Proj. Acct. code:

Lot ID: **1577833**
Control Number:
Date Received: Jun 13, 2022
Date Reported: Jun 17, 2022
Report Number: 2757540

		Reference Number	1577833-41	1577833-42	1577833-43
		Sample Date	Jun 13, 2022	Jun 13, 2022	Jun 13, 2022
		Sample Time	07:30	07:30	07:40
		Sample Location			
		Sample Description	L. F. A / Rm 112 / 19.4 °C	L. F. A / Rm 112 / 19.4 °C	L. F. A / Rm 105 / 19.4 °C
		Matrix	Water	Water	Water
Analyte	Units	Results	Results	Results	Nominal Detection Limit
Metals Extractable					
Lead	Extractable	mg/L	0.0020	0.0016	0.0019
					0.00001

Analytical Report

Bill To: School District #35
20260 - 64 Avenue
Langley, BC, Canada
V3A 4P7Attn: Accounts Payable
Sampled By:
Company:Project ID:
Project Name:
Project Location:
LSD:
P.O.: S00023
Proj. Acct. code:Lot ID: **1577833**
Control Number:
Date Received: Jun 13, 2022
Date Reported: Jun 17, 2022
Report Number: 2757540

Reference Number 1577833-44

Sample Date Jun 13, 2022

Sample Time 07:40

Sample Location

Sample Description L. F. A / Rm 105 /
19.4 °C

Matrix Water

Analyte	Units	Results	Results	Results	Nominal Detection Limit
Metals Extractable					
Lead	Extractable	mg/L	0.0010		0.00001

Approved by:


Max Hewitt
Operations Manager

Analytical Report

Bill To: School District #35
20260 - 64 Avenue
Langley, BC, Canada
V3A 4P7
Attn: Accounts Payable
Sampled By:
Company:

Project ID:
Project Name:
Project Location:
LSD:
P.O.: S00023
Proj. Acct. code:

Lot ID: **1577833**
Control Number:
Date Received: Jun 13, 2022
Date Reported: Jun 17, 2022
Report Number: 2757535

		Reference Number	1577833-13	1577833-14	1577833-15
		Sample Date	Jun 13, 2022	Jun 13, 2022	Jun 13, 2022
		Sample Time	10:00	10:00	10:00
		Sample Location	Vanguard / Rm 3 / 19.4 °C	Vanguard / Rm 3 / 19.4 °C	Vanguard / Rm 1 / 19.4 °C
		Sample Description	Vanguard / Rm 3 / 19.4 °C	Vanguard / Rm 3 / 19.4 °C	Vanguard / Rm 1 / 19.4 °C
		Matrix	Water	Water	Water
Analyte	Units	Results	Results	Results	Nominal Detection Limit
Metals Extractable					
Lead	Extractable	mg/L	0.00042	0.00015	0.0038

Analytical Report

Bill To: School District #35
20260 - 64 Avenue
Langley, BC, Canada
V3A 4P7
Attn: Accounts Payable
Sampled By:
Company:

Project ID:
Project Name:
Project Location:
LSD:
P.O.: S00023
Proj. Acct. code:

Lot ID: **1577833**
Control Number:
Date Received: Jun 13, 2022
Date Reported: Jun 17, 2022
Report Number: 2757535

Reference Number 1577833-16
Sample Date Jun 13, 2022
Sample Time 10:00
Sample Location
Sample Description Vanguard / Rm 1 /
19.4 °C
Matrix Water

Analyte	Units	Results	Results	Results	Nominal Detection Limit
Metals Extractable					
Lead	Extractable mg/L	0.00021			0.00001

Approved by:



Max Hewitt
Operations Manager