

Report Transmission Cover Page

Bill To:	School District #35	Project ID:	Lot ID: 1241565
	20260 - 64th Ave	Project Name:	Control Number: C0066157
	Langley, BC, Canada	Project Location:	Date Received: Nov 27, 2017
	V3A 4P7	LSD:	Date Reported: Nov 30, 2017
Attn:	Terry Walker	P.O.:	Report Number: 2246619
Sampled By:		Proj. Acct. code:	
Company:			

Contact	Company	Address	
Terry Walker	School District #35	20260 - 64th Ave Langley, BC V3A 4P7 Phone: (604) 534-3294 Fax: (604) 534-0841 Email: tewalker@sd35.bc.ca	
<u>Delivery</u>	<u>Format</u>	<u>Deliverables</u>	
Email - Merge Reports	PDF	COC / Test Report	
Email - Single Report	PDF	COA	
Email - Single Report	PDF	Invoice	

Notes To Clients:

The information contained on this and all other pages transmitted, is intended for the addressee only and is considered confidential.
If the reader is not the intended recipient, you are hereby notified that any use, dissemination, distribution or copy of this transmission is strictly prohibited.
If you receive this transmission by error, or if this transmission is not satisfactory, please notify us by telephone.

Analytical Report

Bill To:	School District #35	Project ID:	Lot ID: 1241565
	20260 - 64th Ave	Project Name:	Control Number: C0066157
	Langley, BC, Canada	Project Location:	Date Received: Nov 27, 2017
	V3A 4P7	LSD:	Date Reported: Nov 30, 2017
Attn:	Terry Walker	P.O.:	Report Number: 2246619
Sampled By:		Proj. Acct. code:	
Company:			

Reference Number	1241565-37
Sample Date	November 27, 2017
Sample Time	NA
Sample Location	
Sample Description	West Langley / DF by 14b - S / 17.5 °C
Sample Matrix	Drinking Water

Analyte		Units	Result	Nominal Detection Limit	Guideline Limit	Guideline Comments
Metals Extractable						
Lead	Extractable	mg/L	0.00487	0.00001	0.01	Below MAC

Analytical Report

Bill To:	School District #35	Project ID:	Lot ID: 1241565
	20260 - 64th Ave	Project Name:	Control Number: C0066157
	Langley, BC, Canada	Project Location:	Date Received: Nov 27, 2017
	V3A 4P7	LSD:	Date Reported: Nov 30, 2017
Attn:	Terry Walker	P.O.:	Report Number: 2246619
Sampled By:		Proj. Acct. code:	
Company:			

Reference Number	1241565-38
Sample Date	November 27, 2017
Sample Time	NA
Sample Location	
Sample Description	West Langley / DF by 14b - F / 17.5 °C
Sample Matrix	Drinking Water

Analyte		Units	Result	Nominal Detection Limit	Guideline Limit	Guideline Comments
Metals Extractable						
Lead	Extractable	mg/L	0.000999	0.00001	0.01	Below MAC

Analytical Report

Bill To:	School District #35	Project ID:	Lot ID: 1241565
	20260 - 64th Ave	Project Name:	Control Number: C0066157
	Langley, BC, Canada	Project Location:	Date Received: Nov 27, 2017
	V3A 4P7	LSD:	Date Reported: Nov 30, 2017
Attn:	Terry Walker	P.O.:	Report Number: 2246619
Sampled By:		Proj. Acct. code:	
Company:			

Reference Number	1241565-39
Sample Date	November 27, 2017
Sample Time	NA
Sample Location	
Sample Description	West Langley / Rm 25 - S / 17.5 °C
Sample Matrix	Drinking Water

Analyte		Units	Result	Nominal Detection Limit	Guideline Limit	Guideline Comments
Metals Extractable						
Lead	Extractable	mg/L	0.00697	0.00001	0.01	Below MAC

Analytical Report

Bill To:	School District #35	Project ID:	Lot ID: 1241565
	20260 - 64th Ave	Project Name:	Control Number: C0066157
	Langley, BC, Canada	Project Location:	Date Received: Nov 27, 2017
	V3A 4P7	LSD:	Date Reported: Nov 30, 2017
Attn:	Terry Walker	P.O.:	Report Number: 2246619
Sampled By:		Proj. Acct. code:	
Company:			

Reference Number	1241565-40
Sample Date	November 27, 2017
Sample Time	NA
Sample Location	
Sample Description	West Langley / Rm 25 - F / 17.5 °C
Sample Matrix	Drinking Water

Analyte		Units	Result	Nominal Detection Limit	Guideline Limit	Guideline Comments
Metals Extractable						
Lead	Extractable	mg/L	0.00211	0.00001	0.01	Below MAC

Analytical Report

Bill To:	School District #35	Project ID:	Lot ID: 1241565
	20260 - 64th Ave	Project Name:	Control Number: C0066157
	Langley, BC, Canada	Project Location:	Date Received: Nov 27, 2017
	V3A 4P7	LSD:	Date Reported: Nov 30, 2017
Attn:	Terry Walker	P.O.:	Report Number: 2246619
Sampled By:		Proj. Acct. code:	
Company:			

Reference Number	1241565-41
Sample Date	November 27, 2017
Sample Time	NA
Sample Location	
Sample Description	West Langley / Staff Rm - S / 17.5 °C
Sample Matrix	Drinking Water

Analyte		Units	Result	Nominal Detection Limit	Guideline Limit	Guideline Comments
Metals Extractable						
Lead	Extractable	mg/L	0.00643	0.00001	0.01	Below MAC

Analytical Report

Bill To:	School District #35	Project ID:	Lot ID: 1241565
	20260 - 64th Ave	Project Name:	Control Number: C0066157
	Langley, BC, Canada	Project Location:	Date Received: Nov 27, 2017
	V3A 4P7	LSD:	Date Reported: Nov 30, 2017
Attn:	Terry Walker	P.O.:	Report Number: 2246619
Sampled By:		Proj. Acct. code:	
Company:			

Reference Number	1241565-42
Sample Date	November 27, 2017
Sample Time	NA
Sample Location	
Sample Description	West Langley / Staff Rm - F / 17.5 °C
Sample Matrix	Drinking Water

Analyte		Units	Result	Nominal Detection Limit	Guideline Limit	Guideline Comments
Metals Extractable						
Lead	Extractable	mg/L	0.00369	0.00001	0.01	Below MAC

Approved by: 
Mathieu Simoneau
Operations Manager

Data have been validated by Analytical Quality Control and Exova's Integrated Data Validation System (IDVS).
Generation and distribution of the report, and approval by the digitized signature above, are performed through a secure and controlled automatic process.

Methodology and Notes

Bill To:	School District #35	Project ID:	Lot ID: 1241565
	20260 - 64th Ave	Project Name:	Control Number: C0066157
	Langley, BC, Canada	Project Location:	Date Received: Nov 27, 2017
	V3A 4P7	LSD:	Date Reported: Nov 30, 2017
Attn:	Terry Walker	P.O.:	Report Number: 2246619
Sampled By:		Proj. Acct. code:	
Company:			

Method of Analysis

Method Name	Reference	Method	Date Analysis Started	Location
Trace Metals (extractable) in Water (Surrey)	US EPA	* Determination of Trace Elements in Waters and Wastes by ICP-MS, 200.8 <i>* Reference Method Modified</i>	Nov 28, 2017	Exova Surrey

References

US EPA	US Environmental Protection Agency Test Methods
--------	---

Guidelines

Guideline Description	Health Canada GCDWQ
Guideline Source	Guidelines for Canadian Drinking Water Quality, Health Canada, February 2017
Guideline Comments	MAC = Maximum Acceptable Concentration AO = Aesthetic Objective OG = Operational Guideline for Water Treatment Plants Refer to Health Canada GCDWQ for complete guidelines and additional drinking water information at www.hc-sc.gc.ca

The comparison of test results to guideline limits is provided for information purposes only. This is not to be taken as a statement of conformance / nonconformance to any guideline, regulation or limit. The data user is responsible for all conclusions drawn with respect to the data and is advised to consult official regulatory references when evaluating compliance.

Please direct any inquiries regarding this report to our Client Services Group or to the Operations Manager at the coordinates indicated at the top left of this page.

Results relate only to samples as submitted.

The test report shall not be reproduced except in full, without the written approval of the laboratory.